

CERTIFICATE OF COMPLIANCE

Certificate Number 20180301-SA44668
Report Reference SA44668-20160808
Issue Date 2018-MARCH-01

Issued to: Conex Universal Limited
Global House
95 Vantage Point, The Pensnett Estate
Kingswinford
DY6 7FT UNITED KINGDOM

This is to certify that representative samples of REFRIGERATION, FITTINGS
USL, CNL – Refrigeration Fittings, >B< MaxiPro, MPA Series.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 207 - Standard for Refrigerant-Containing Components and Accessories, Nonelectrical
CSA C22.2 No. 140.3-15 - Standard for Refrigerant-containing Components for use in Electrical Equipment
UL 109 - Standard for Tube Fittings for Flammable and Combustible Fluids, Refrigeration Service, and Marine Use - Edition 6

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

